

RESOLUTION

To Award Bid No. 24-13 to Pennsylvania Transformer Technology, Inc. for Two (2) 3-PH Power Transformers 15/20/25 MVA at a Cost not to Exceed \$1,533,898.00

WHEREAS, the City of Alexander City has let bids for two (2) 3-PH Power Transformers 15/20/25 MVA; and

WHEREAS, specifications were submitted and placed on file with the City Clerk; and

WHEREAS, said bid will be paid from the Light Department Capital budget; and

WHEREAS, the invitation for bid was posted on April 15, 2024 in the Municipal Complex; and

WHEREAS, four (4) sealed bids were received, opened and read in public on April 15, 2024 at 2:00 p.m.; and

WHEREAS, the bids were submitted to the City Council of Alexander City at their May 6, 2024 meeting.

NOW, THEREFORE, BE IT RESOLVED that the City Council of the City of Alexander City hereby awards bid No. 24-13 to Pennsylvania Transformer Technology, Inc for two (2) 3-PH Power Transformers 15/20/25 MVA in an amount not to exceed \$766,949.00 each.

BE IT FURTHER RESOLVED by the City Council of the City of Alexander City that the mayor is hereby authorized to sign any contract or agreements as part of this bid award.

ADOPTED THIS 6TH DAY OF MAY, 2024.

FOR PUBLIC RELEASE

By: Audrey "Buffy" Colvin, President
Alexander City Council

AUTHENTICATED THIS 6TH DAY OF MAY, 2024.

FOR PUBLIC RELEASE

By: Stephanie J. Southerland,
City Clerk


APPROVED.

FOR PUBLIC RELEASE

By: Curtis "Woody" Baird,
Mayor

Yeas: Tapley, S. Hardy, E. Brown, Colvin, C. Brown, Keel

Nays: None



P.O. Box 2233 (36202)
300 East 7th Street (36207)
Anniston, AL
Phone 256-237-0891

April 18, 2024

Ms. Sasha Stewart
Public Works Specialist
281 James D. Nabors Drive
Alexander City, AL 35010

RE: New Dadeville Road Substation
Transformer Bid Recommendations

Dear Ms. Stewart:

Find enclosed separate Certified Bid Tabulation for the Substation Transformers as bid on April 15, 2024.

We recommend that the two (2) transformers, manufactured by Pennsylvania Transformer Technology, Inc. (PTT), be purchased from PTT, the low bidder, with a low Bid of \$1,533,898 (\$766,949 each). We recommend that you review the PTT Standard Terms and Conditions of Sale and, if in agreement with all stipulations, issue a Purchase Order as soon as possible. You should contact Mr. Jim Farrar with Whitehead & Associates (205-218-3432) for instructions on issuing the Purchase Order.

There are two (2) Options for Payment. Option 1 (recommended) requires 50% of contract price due upon the order, 25% due upon receipt of core steel and copper, 20% due upon completion of factory acceptance testing, with remaining 5% balance due upon shipment. This Option allows the Contract Price to remain fixed. Option 2 offers escalated pricing with payment terms, smaller percentages due up front, but with price escalation clauses. We have attached a separate copy of this page from the bid documents to help you better understand these PTT Options.

All original bid documents will be returned next week, for your records.

If we can be of further assistance on this matter, please don't hesitate to call.

Sincerely,

STEWART ENGINEERING, INC.

FOR PUBLIC RELEASE

Lance Junkin

LJ:tcv
Enclosures

BID TABULATION

LOCATION: Light Department City of Alexander City
Alexander City, Alabama

BID OPENING DATE: April 15, 2024 at 2:00 P.M.
PROJECT: 3-PH Power Transformer 15/20/25 MVA
BID ON TWO (2) TRANSFORMERS – BID #24-13

BIDDER	MANUFACTURER	NO LOAD LOSSES (KW) (@ \$6000/KW) (EACH)	LOAD LOSSES (KW) (@ \$2000/KW) (EACH)	AUX LOSSES (KW) (@ \$1500/KW) (EACH)	BASE BID (EACH)	EVALUATED BID (EACH)	BASE BID TOTAL	EVALUATED BID TOTAL	DELIVERY	REMARKS
1. Anixter (South) Pensacola, AL										
2. Ashby Co., Inc. Birmingham, AL										
3. Cape Electric Decatur, AL										
4. Delta Star Lynchburg, VA										NO BID.
5. Gresco Dothan, AL										
6. Hitachi Energy Crystal Springs, MS	Hitachi Energy	10.5	50.6	2.1	\$1,221,220.00	\$1,388,570.00	\$2,442,440.00	\$2,777,140.00	96-100 Wks.	5 Yr. Warranty. Extra Charges for Freight, Inspection & Assembly/Testing
7. Pennsylvania Trfmr Canonsburg, PA	PTT	12.5	53.5	3.2	\$766,949.00	\$953,749.00	\$1,533,898.00	\$1,907,498.00	78-82 Wks.	5 Yr. Warranty.
8. Virginia Transformer Corp Roanoke, VA	VTC	11	50	2	\$1,094,500.00	\$1,263,500.00	\$2,189,000.00	\$2,527,000.00	55-60 Wks.	5 Year Warranty.

I hereby certify that the above is a true and correct tabulation of bids received on April 15, 2024 for two (2) 3-PH Power Transformers 15/20/25 MVA.

BY

FOR PUBLIC RELEASE

STEWART ENGINEERING, INC.